

145 Adams Avenue, Hauppauge, NY 11788 USA Tei: (631) 435-110 • Fax: (631) 435-1824 w w w c e n t r a l s e m i c o m mailto:processchange@centralsemi.com http://www.centralsemi.com/processchange

## PCN #130 Notification Date: 2 November 2011

# **Product / Process Change Notice**

## Parts Affected:

CBRSDSH5-40 and CBRSDSH5-60 full wave Schottky bridge rectifiers manufactured in the epoxy molded SMDIP case.

#### Extent of Change:

The CBRSDSH5-40 and CBRSDSH5-60 are being discontinued and replaced with the CBRSDSH2-40 and CBRSDSH2-60.

### Reason for Change:

The CBRSDSH5-40 and CBRSDSH5-60 were released with an Average Forward Current rating of 5 amps at T<sub>A</sub>=60°C, based on pulse testing. Bridge rectifiers need to be rated at I<sub>0</sub> (Average Forward Current) and at T<sub>A</sub>=25°C. Accordingly, the proper rating for this device is I<sub>0</sub>=2 amps at T<sub>A</sub>=25°C. The characteristics of I<sub>F</sub> test conditions up to 5 amps (pulsed) and V<sub>F</sub> limits will be unchanged.

### Effect of Change:

There is no change in the internal construction of the device including the chip size. The CBRSDSH2-40 and CBRSDSH2-60 are being manufactured identically to the CBRSDSH5-40 and CBRSDSH5-60; the change affects the Average Forward Current rating (I<sub>0</sub>) which is being changed from 5A to 2A, hence the part # change.

#### **Qualification:**

Devices were mounted on a 2" square FR4 PCB using the SMDIP minimum recommended mounting pad geometry. AC voltage was applied and varied until the average output current  $I_0$  of 2 amps at T<sub>A</sub>=25°C was achieved and held continuously, with no failures.

#### Effective Date of Change:

Q4 2011.

### Sample Availability:

Please contact Salesperson or Manufacturer's Representative.